

Certificate of constancy of performance



according to Regulation (EU) No. 305/2011

Certificate No.: 1008-CPR-MC 69266491 0001

Report No.: HU232SO4 001

Applicant: Zhongshan Guta Fire Equipment Technology Co., Ltd.
Xingye Rd., Huoju District, Zhongshan 528437 Guangdong, P.R.
China

Manufacturer: Zhongshan Guta Fire Equipment Technology Co., Ltd.
Xingye Rd., Huoju District, Zhongshan 528437 Guangdong, P.R.
China

Manufacturing plant: Zhongshan Guta Fire Equipment Technology Co., Ltd.
Xingye Rd., Huoju District, Zhongshan 528437 Guangdong, P.R.
China

Product: Smoke Alarm

Identification: AW-D603, AW-D605, AW-D603L, AW-D605L
Household Smoke Alarm
Intended use: Fire Safety

FPC Report No.: HU23UJLT 001
Test Report: CN22QML2 001

**System of assessment
and verification:** 1

Tested according to: EN 14604:2005
EN 14604:2005/AC:2008

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2023-01-24 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:

Budapest, 2022-01-24

Kristof Kertesz

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	[®] EN 14604:2005 EN 14604:2005/AC:2008
Repeatability	Pass	
Directional dependence	Pass	
Initial sensitivity	Pass	
Air movement	Pass	
Dazzling	Pass	
Dry heat (55±2°C, 2h)	Pass	
Cold (operational) (0±2°C, 2h)	Pass	
Damp heat (operational) (40±2°C, 93±3%, 4 days)	Pass	
Sulphur dioxide (SO ₂) corrosion (25 °C; 93 %; 25 ppm; 4 days)	Pass	
Impact (1,9±0,1 J; 1 time)	Pass	
Vibration (operational) (10 to 150 Hz; 5m/s ² ; 3 axes)	Pass	
Vibration (endurance) (10 to 150 Hz; 10m/s ² ; 3 axes)	Pass	
Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	
Fire sensitivity (TF2; TF3; TF4; TF5)	Pass	
Battery fault warning	Pass	
Sound output	Pass	
Sounder durability	Pass	
Inter-connectable smoke alarms	N/A	
Alarm silence facility	N/A	
Variation in supply voltage	Pass	
Battery reversal	Pass	
Back-up power source	N/A	
Electrical safety	Pass	

Certification Body
Date of issue:

Budapest, 2023-01-24



.....

Kristof Kertesz